

# VMEBUS INPUT/OUTPUT BOARDS

## AVME948x General-Purpose Digital I/O

- Model AVME9480: front panel access
- Model AVME9481: P2 access


These digital input/output boards interface solid-state or mechanical control relays and other discrete industrial logic devices to the VMEbus. The interfacing is accomplished by providing 64 general purpose I/O points (or lines). Each of the 64 points is selectable as an input, an output, or both - depending on the application.

These boards can handle inputs from a low range of 0 to 5V DC to a high range of 0 to 30V DC. The host can read each of the points configured as an output.

A variety of features includes host interrupt capability and adjustable input threshold.

### Features

- 64 points of bidirectional I/O
- I/O range of 0 to 30 volts
- I/O points configurable as eight 8-bit ports or four 16-bit ports
- One 8-bit port (Port 0) for handshaking with latch and interrupt capability
- Read state of points configured as outputs
- Open collector output
- Adjustable input threshold
- Status LEDs
- Built-in protection diodes for driving relay coils
- Byte or word data transfers
- Compatible with industry-standard plug-in solid-state relays and termination panels



AVME9480 and AVME9481 boards offer a price/performance balance that is ideal for a broad range of I/O applications.

### Specifications

#### General

I/O points per board: 64; each point is programmable as an input and/or an output.

Interrupt capability: 8 level-selectable interrupt lines with programmable masks.

#### Digital Input

Input voltage range: 0 to 30V DC.

Input threshold:

High to low:

Internal reference supply:

$V_{IL} = 1.0V$  DC nominal.

External reference supply:

$V_{IL} = (.448 \times REF) - 1.22V$  DC nominal.

Low to high:

Internal reference supply:

$V_{IH} = 2.25V$  DC nominal.

External reference supply:

$V_{IH} = (.448 \times REF) + 0.025V$  DC nominal.

Input hysteresis: 1.2V DC nominal.

Input current (per point):

$I_{IL} = -0.2\mu A$  at 0V,  $V_{REF} = 5V$ .

$I_{IH} = 61\mu A$  at 30V DC.

External reference supply: 2.75 to 27.5V DC.

#### Digital Output

Output type: open collector with optional pull-up resistor.

Output voltage range: 0 to 30V DC.

Output current (per point):  $I_{OL} = 100mA$  maximum.

#### Power Supply Requirements

Power: +5V DC +5%/-2.5% @ 1.6 A, typical.

#### Environmental

Operating temperature: 0 to 70°C (32 to 158°F).

Relative humidity: 5 to 95%, non-condensing.

Isolation: Non-isolated.

#### Connector

1P, P2: IEC Type 603-2-C096MX-xxx (96 pin DIN).

P3, P4: (AVME9480 only) 50 pin male header connector.

#### VME Compliance

Meets VME Specifications per revision C.1 dated October 1985 and IEC 821-1987.

Data transfer bus: A16: D16/D08 (EO) DT8 slave.

Address modifier codes: 29H, 2DH.

Interrupt request levels: IRQ(1) - IRQ(7) eight programmable vectors.

Memory map: short I/O space occupying 1K.

### Ordering Information

#### AVME9480:

Front cable access

#### AVME9481

Rear cable access (P2), see warning below


**WARNING:** Do not plug AVME9481 into a P2 backplane slot. The middle row of P2 pins are used for I/O. Instead, use a 9921 adapter and P2 backplane with an open slot. See termination products for more information.

For software, see Page 58. For wiring hardware, see Pages 60-65. For signal conditioning, see Page 66.

108

5/15/03 0900 24-5 ANODE TAPS 4 TIMES OVERNIGHT  
MEASURED CURRENT = -0.48 (MOST NEG I'VE  
HAD HV CHANNEL?)

5/16/03 ACCESS - WORK ON FC SCANNER  
1. REMOVE RACK SIDE RAIL - NO HELP.  
2. ADD STEEL SHEETS FOR SHIELDING  
FROM BACK:



← RACK SIDE WALL IS MAGNETIC

AT 28 KV:

$\Delta = 2.2$     76.588    76.585     $\Delta = 5.8$  ) \* = FIXED  
 $\Delta = 1.7$     76.592    76.592     $\Delta = 1.4$  )    FOR A POL

5/18/03 2 FEE LUPS GO OUT @ ~1800. AT MIDNIGHT ALL OF  
RACK 2B3 GOES OUT - INTERLOCK.  
ACCESS ON 5/19 - FIND BLOWER VERY HOT + 2  
CIRCUIT BREAKERS TRIPPED (= 1800 EPISODE).  
FIND SPARE BLOWER + INSTALL - ALL LUPS COME  
ON. THIS BLOWER WAS THE ONE THAT I USED  
TO KICK TO GET PRESSURE SWITCH ON AFTER  
SKID WAS OFF. KENNY REPAIRED PRESSURE SWITCH  
~2 MOS AGO. DANNY LOOKING AT FAN BLOWER  
MOTOR NOW (BEARING WAS VERY STIFF).  
CHECKING ON LIFETIME OF BLOWER AND GETTING  
SPARES.

10/8/03 → TURN ON BEFORE ROLL-IN - 2B3 PRESSURE SW!  
AGAIN DOESN'T CLEAR! KICKING DOESN'T HELP.

10/22/03 AFTER ROLL IN - BOTH

10/13/2003 TEST FIELD CABE - DET ROLLED OUT, SVT, SSD, FT.

NO ~~ARK~~ BLOWER NO MAGNET

	5KV	10KV	15KV	20KV	25KV	28KV	30KV
OFCW	13.765	27.422	41.088	54.737	68.377	76.574	82.032
IFCW	13.765	27.422	41.087	54.737	68.374	76.576	82.038
OFC E	13.764	27.421	41.085	54.735	68.381	76.573	82.036
IFC E	13.765	27.422	41.085	54.733	68.382	76.574	82.037

OK

10/13/2003 AFTER POWER OUT ON FRI INTERLOCK FOR 2B7 FEES DIDN'T CLEAR. LOOKS TO BE WATER SIGNAL ALSO, 2B3 WENT BAD AGAIN LAST WEEK. CROSS CONNECT LOOKED LIKE FRAMMY PRESSURE SWITCH AGAIN.

DISCOVERED THAT PRESSURE SWITCHES ARE ADJUSTABLE + WE HAVE TWO KINDS - ONE HAS LOWER RANGE THAN THE OTHER.

NOT FIXED YET - 2B3 BLOWER CABLE IS UNPLUGGED FOR NOW.

10/14/03 ON TURNING OFF BLOWER SWITCH FOR 2B6 DOESN'T SHUT OFF LVPS IN THAT RACK. ARGH!

ALSO, MEASURE PRESSURE IN BLOWER IN 2B1

= .7" H<sub>2</sub>O

10/27/03 1000 AFTER ROLL IN - BOTH 2B6 AND 2B7 WOK. OK. THUS TURNING OFF BLOWER IN 2A6 DROPS INTERLOCK. 2B7 CROSS CONNECT CLEARS OK. SO

PHIL REPLACES PRESSURE SWITCH IN 2B3 AGAIN PUT IN ONE WITH LOWER PRESS RANGE

START REPLACING FEES

DEAD BAND ON "00" TYPE IS VERY WIDE RANGE = .07 TO .15. WHEN BLOWER GOES ON, WORDS WELL. WHEN BLOWER TURNED OFF

SEE  
146  
WOULD  
USE THE  
"01"

TURN ON ALL SYSTEMS TO FULL VOLTAGE  
(INCL 20-5) 20-5 TRIPS AFTER ~ 20 MIN

GAIN CH SHOWS NOTHING - NO NOISE, NO Fe, NO PULSES  
RESET MCA ON PLATFORM ... STILL NOTHING.  
EMAIL PAUL

1/6/03 TURN OFF HV (EXCEPT 6G)

8/03 1000 TRY A LASER RUN  
6G 20 OUTER STAYS AT 69.5 ALL NIGHT

15/30 LASER RUN - BEAMS LOOK ~ WEAK  
AZ CHECKING POWER METER  
TIMING AT TED LOOKS OK 106, 216, 329  
 $\Delta = 110$

20/03 0900 LASER LOOKS GOOD - IT WAS N2 IN THE GAS.

24/03 CROSS CONNECT IN 2B7 AGAIN FLAKY. ON  
TURNING ON FBES NONE OF 4, 5, 6 COME ON (2B7)  
BUT SLOW CONTROLS DOESN'T SHOW BAD INTERLOCK.  
FIND CROSS CONNECT RED LED ON - CYCLE POWER  
ON VME CRATE - AFTER REBOOT ~~LED~~ LED ~ 1/2 ON  
& THEN FBES OUT - VER 7 WORKS. OK NOW.

→ FIXED? BY PHIL - FOUND THAT MODULE HAD A BAD  
10K  $\Omega$  PULL DOWN RESISTOR IN FAIL SAFE MOD  
WE HAD MADE. HE PUTS IN GOOD 10K  $\Omega$ .

26/03 FIND ONE TPC TEMP THERMOCOUPLE READING 88°  
(= INNER ROD 7). WE TRY & LOOK INSIDE W/   
BORE SCOPE BUT NO GO. FAN BLOWING ON OUTSIDE  
BRINGS IT DOWN ~ 2°. (THIS ONE WAS 116°  
LAST YEAR - MAYBE 82° BUT WAS NOT LOOKED AT.

TRY TURNING ON ONE BY ONE -  
IF ALL SIX OFF, T = AMBIENT ~ 79°  
TURN ON ROD 1 - 79°  
TURN ON ROD 2 - 79°  
TURN ON ROD 3 - 86° (ROD 3 = OUTER MANIFOLD!  
SO THEORY IS THAT SENSOR FOR INNER ROD 7 IS NOT GLUED  
TO MANIFOLD & IS HANGING JUST ABOVE ROD 3.

1/11/07) MAGNET WORK FINISHED - HAD 2 FAST CRASHES FROM FULL FIELD.

CHECK FC AGAIN - CURRENTS OK, AS PER PG 7. Δ = TURN ALL OFF

1/25/07) 1100) LEEROY 145P MAINFRAME (FOR OUTER SECTORS) COME BACK FROM VOLTTRONICS AGAIN. (REPLACED MOTHER BOARD) PUT IT IN + IT SEEMS TO WORK. LEAVE ON FOR 24 HR. PUT MAIN POWER 145P IN BOX + PUT ON CLEAN ROOM ROOF. CAN BE TPC OR SVT SPARE.

1/26/07) REPAIRED 1458 STILL OK - SHOT IT DOWN.

2/7/07) DANNY RE-DOES THE INTERLOCKS FOR THE LVPS. PROBLEM WAS THAT IF THE INTERLOCK CABLE TO THE BLOWER WAS UNPLUGGED (BNC) THE LVPS STAYED ON - SO NOT FAIL SAFE. DANNY RE-DOES THE LOGIC. I TEST THE LVPS FOR THE MWPC FEES:

1. UNPLUG BLOWER CABLE - LVPS GO OFF
2. TURN OFF BLOWER - " " "

WILL TEST WATER SUPPLY THIS WEEK

DANNY NOW MODIFYING RACK ROW 2B LVPS (ALL)

2/12/07) 1400. PUT POLARITY REVERSING CABLE IN GG FOR SECTOR 8 (INNER) THIS SECTOR HAS WHAT ARE ASSUMED TO BE FLAKING GG WIRES IN 2 PLACES THAT CAUSE A GRID LEAK. REVERSE POLARITY SEEM TO LEAK 1 MONTH. CLOSE THIS LEAK.

JOBS  
MOVED  
OUTER BE  
MOVED  
3/6/07

2/17/07) 1000 PUT 1 MΩ IN IFC EAST RESISTOR CHAIN. WAS 2 MΩ AT END OF RUN 6.  
TEST FC

	2 KV	5 KV	10 KV	15 KV	20 KV	25 KV	28 KV	28 KV
FCW	5.558	13.751	27.395	41.052	54.691	68.325	76.524	76.508
OFCB	5.557	13.750	27.396	41.048	54.687	68.321	76.516	76.505
IFCW	5.557	13.750	27.397	41.049	54.688	68.321	76.515	76.505
IFCE	5.542	13.713	27.321	40.936	54.538	68.173	76.349	76.451
					Δ = 150	Δ = 150	Δ = 160	Δ = 50

REMOVE TRANSITION MODULE -

35

ALSO, CAPUT INTO +12V LOWER TRIP LIMIT DOES NOT WORK.

1/16/08 FINALLY BACK TO NORMAL FOR CRATE 59.  
1630 FOUND SMALL SLOW WATER LEAK IN RADIATOR ABOVE CRATE 59 - DROPS MAY HAVE GONE INTO PS. REPLACE RADIATOR  
1ST SPARE CRATE DRAWS 20 A ON +12V, THEN TRIPS ON OVERCURRENT - PS SMOKES  
MAY HAVE BEEN DUE TO TRANSITION MODULE CONNECTOR CARD TOUCHING SIDE OF CRATE.  
GET YET ANOTHER PS FROM DANNY - REPLACE TRANSITION MODULE CONNECTOR CARD (BLOWN ON BOARD FUSE).  
NEW PS + CRATE LOOK GOOD - NO VOLTAGE SPILLES.  
BOOT UP WITH REPLACEMENT PROC - OLD PULSER PROCESSOR (SEE PG 33).

1/17/08 0900 CRATE 59 GOOD ALL NIGHT.

28/08 0900 END OF DAU. ACCESS DAY

1. FOUND COOLING FAILURE ON RACK 2B3 - FIND BLOWER VERY HOT - CALL KEN FOR REPLACEMENT.

2. TOMMO PRACTICING WITH TPX FAST-RO. UNPLUG GG + TURN OFF GG VOLTAGES.

630: TOOK ALL DAY TO REPLACE - BLOWER WAS FROZEN BUT ALSO HAD PROBLEMS w/ PRESSURE SWITCH.  
2ND PRESSURE SWITCH FINALLY WORKS.

27/08 LAST ACCESS

1. INVESTIGATE TPX LVPS #6 - HAD TROUBLE 2 DAYS AGO TURNING ON - KEPT OSCILLATING ON/OFF <sup>REPLACED PS</sup>
2. CREW REPORTS SC ALARMS DIDN'T WORK FOR ANODE TRIPS - CHECKED OK
3. YURI WANTS GG PROC REBOOTED